



## **CAPRICORN DISTRICT MUNICIPALITY**

### **TENDER ADDENDUM TENDER NUMBER: INF-W04/2022/2023 ROSENKRANTZ WATER SUPPLY**

Please find herewith Addendum No. 1 which forms an integral part of the above-mentioned contract.

- **Change a Non-Return Valve size from 75mm diameter to 110mm diameter on item 6.11, 8.2.3.3(ii) of Section 1200L**

**Note: you are still allowed to make these changes using black ink and sign next to the changes.**

#### **PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM AS FOLLOWS:**

and

1. Complete the attached acknowledge of receipt and submit the completed form with your tender.

Failure to acknowledge receipt of this Addendum may prejudice your tender.



**CAPRICORN DISTRICT MUNICIPALITY**

**THIS ACKNOWLEDGEMENT OF RECEIPT OF  
ADDENDUM MUST BE SUBMITTED TOGETHER WITH  
THE TENDER DOCUMENT**

Capricorn District Municipality  
P.O. Box 4100  
POLOKWANE  
0700

Sir/Madam

**CONTRACT NO: INF-W04/2022/2023  
ROSENKRANTZ WATER SUPPLY**

ADDENDUM NO. 1

I/We herewith acknowledge receipt of Addendum No. 1 for the above-mentioned Tender.

SIGNATURE: .....

COMPANY: .....

DATE: .....